



ENERGY STAR HOME REPORT

Date: August 08, 2007 Rating No.: Simulated Performance Analysis
Building Name: Skyview Homes Rating Org.: EnergyLogic, Inc.
Owner's Name: Skyview Homes Phone No.: 970.532.3220 1.800.315.0459
Property: Teton Rater's Name: Peter Oberhammer
Address: New Castle, CO 81647 Rater's No.: 023
Builder's Name: Skyview Homes
Weather Site: Glenwood Springs, CO Rating Type: Based On Plans
File Name: Teton.blg Rating Date: 08/08/07

Normalized, Modified End-Use Loads (MMBtu/year)

Table with 3 columns: Category, ENERGY STAR, As Designed. Rows include Heating, Cooling, Water heating, Lighting & Appliances, Total, and HERS Index.

ENERGY STAR Mandatory Requirements

Form with checkboxes for Thermal Bypass Inspection Checklist, Ductwork Requirements, ENERGY STAR Products, and ENERGY STAR Scoring Exceptions.

\* Thermal Bypass Checklist and ENERGY STAR Products are not checked in REM/Rate at this time.

This home MEETS OR EXCEEDS the energy efficiency requirements for designation as an EPA ENERGY STAR Qualified Home.

Table with 2 main sections: Pollution Prevented (Type of Emissions, Reduction) and Energy Cost Savings (\$/year) (Heating, Cooling, Water Heating, Lights & Appliances, Total).

The energy savings and pollution prevented are calculated by comparing the Rated Home to the Reference Home as defined in the "Mortgage Industry National Home Energy Rating Systems Standards" as promulgated by the Residential Energy Services Network (RESNET).

REM/Rate - Residential Energy Analysis and Rating Software v12.42

This information does not constitute any warranty of energy cost or savings. © 1985-2007 Architectural Energy Corporation, Boulder, Colorado.



# Home Energy Rating Certificate

Skyview Homes

Teton

New Castle, CO 81647



**5 Stars Plus  
Based On Plans**

## Uniform Energy Rating System

1 Star	1 Star Plus	2 Stars	2 Stars Plus	3 Stars	3 Stars Plus	4 Stars	4 Stars Plus	5 Stars	5 Stars Plus
500-401	400-301	300-251	250-201	200-151	150-101	100-91	90-86	85-71	70-0

## Energy Efficient

**HERS Index: 69**

### General Information

Conditioned Area: 4035 sq. ft.      HouseType: Single-family detached  
 Conditioned Volume: 38313 cubic ft.      Foundation: Conditioned basement  
 Bedrooms: 4

### Mechanical Systems Features

Heating: Fuel-fired air distribution, Natural gas, 93.0 AFUE.  
 Water Heating: Conventional, Natural gas, 0.58 EF.  
 Duct Leakage to Outside: 80.00 CFM.  
 Ventilation System: Exhaust Only: 70 cfm, 13.0 watts.  
 Programmable Thermostat: Heating: Yes      Cooling: Yes

### Building Shell Features

Ceiling Flat: R-38      Exposed Floor: NA  
 Vaulted Ceiling: NA      Window Type: Low E .35 /.35  
 Above Grade Walls: R-25      **Infiltration:**  
 Foundation Walls: R-13.0, R-11.0      Rate: Htg: 0.10 Clg: 0.10 ACHnat  
 Slab: R-0.0 Edge, R-0.0 Under      Method: Blower door test

### Lights and Appliance Features

Percent Fluorescent Pin-Based: 10.00      Clothes Dryer Fuel: Electric  
 Percent Fluorescent CFL: 0.00      Range/Oven Fuel: Electric  
 Refrigerator (kWh/yr): 775.00      Ceiling Fan (cfm/Watt): 0.00  
 Dishwasher Energy Factor: 0.46

The Home Energy Rating Standard Disclosure for this home is available from the rating provider.

**REM/Rate - Residential Energy Analysis and Rating Software v12.42**

This information does not constitute any warranty of energy cost or savings.  
 © 1985-2007 Architectural Energy Corporation, Boulder, Colorado.

**Rating Number: Simulated Performance Analysis**

Certified Energy Rater: Peter Oberhammer

Rating Date: 08/08/07

Rating Ordered For: Skyview Homes

### Estimated Annual Energy Cost

Based On Plans

Use	MMBtu	Cost	Percent
Heating	58.3	\$482	27%
Cooling	0	\$0	0%
Hot Water	23.4	\$186	10%
Lights/Appliances	44.3	\$923	52%
Photovoltaics	-0.0	\$-0	-0%
Service Charges		\$196	11%
<b>Total</b>		<b>\$1788</b>	<b>100%</b>

**This home meets or exceeds the minimum  
criteria for all of the following:**

- EPA Energy Star Home
- ASHRAE Standard 90.2 - 1992
- 2003 International Energy Conservation Code
- 2004 International Energy Conservation Code
- 2006 International Energy Conservation Code

### Home Energy Rating Provider

**EnergyLogic, Inc**

P.O. Box N

Berthoud, CO 80513

Phone # 1.800.315.0459

www.nrglogic.com



Certified Energy Rater